




# California 33% RPS



## Presentation to the SF PES Chapter

by  
Barney Speckman  
and  
Anu Pandey



*June 2009*

# Overview

- **What is the 33% Renewable Portfolio Standard (RPS)**
- **How would it work**
- **How might the 33% RPS requirements be met**
- **What are some of the challenges**
- **What are the opportunities**
- **Q&A**

# *What is the 33% RPS*

- **AB 32 (2006) Requires California to reduce GHG emissions to 1990 levels by 2020**
- **California Air Resources Board (CARB) has been assigned task of developing a plan to implement AB 32**
- **CARB's proposed plan includes establishing a 33% Renewable Portfolio Standard for the California electric industry**
- **Currently a mandatory 20% RPS (by 2010) is in place for the states investor owned utilities (PG&E, SCE, SDG&E) with many Municipal Utilities voluntarily implementing RPS targets**

## *How would it work*

- **Would require 33% of the amount of energy sold to customers to be produced by eligible renewable resources**
- **Applies to all companies selling energy at retail in CA**
- **Sets 2020 as date to meet the 33% Standard**
- **Establishes penalties for non compliance**
- **Legislation being discussed in Sacramento**

## *How might the 33% RPS be met*

# **No one knows for certain!!!**

- Many degrees of freedom in the implementation thus many uncertainties will have to be dealt with
- What technologies will be utilized?
- Where, when and what plants will be built?
- How will the power be delivered to customers?
- What other infrastructure will be needed?

**Several studies have/are being conducted**

# *Possible 33% Renewable Futures*

- **Recent CPUC study used to consider several possible futures as a way to bracket the future implementation of the 33% RPS**
- **Examines cost, difficulty, GHG reductions for several mixes of technology and infrastructure requirements**
- **Looks at:**
  - 33% Reference
  - High Wind
  - High Imports
  - High Distributed Generation

# Possible 33% Futures (Cont'd)

- Energy and Capacity Requirements based upon CPUC Forecast compared to 2007

Renewable Portfolio Standard	Additional Energy Required	Additional Renewable Capacity Required (Approx)
20% RPS	35 TWh	10,000 MWs
33% RPS	75 TWh	22,000 MWs

2007 Renewable Energy was 27 TWh

TWh =  $10^{12}$  Watt-hours

# *Lets Look at the Technologies in California*

- **Major contributors (potentially) to new production**
  - Wind
  - Solar Thermal
  - Solar PV
  - Geothermal
- **Lesser contributors to new production**
  - Biomass
  - Biogas
  - Small Hydro
- **Majority of new renewables in California are in Southern part of the state**

# New Renewable Additions Under CPUC Cases

	High Out Of State Delivered	High Wind	Distributed Generation
<b>California</b>			
Biogas	279	279	279
Biomass	575	634	403
Geothermal	1,655	1,655	1,415
Solar PV	969	1,162	<b>15,068</b>
Solar Thermal	2,101	3,163	1,095
Wind	5,756	<b>9,575</b>	4,484
Sub Total	11,357	16490	22,766
<b>Out of State</b>			
Biomass	87	87	87
Geothermal	938	58	58
Solar Thermal	534	534	534
Wind	6,910	<b>4,802</b>	3,302
Sub Total	<b>8,496</b>	5,496	3,996
<b>Total</b>	<b>19,853</b>	<b>21,986</b>	<b>26,762</b>

# Nexant Study - Assumed Locations of Incremental Renewables in California - 33% RPS, 2020



# *Lets Look at the Technologies in California Wind Generation*




# *Wind Generation Characteristics*

- **Low cost technology on an energy basis**
- **Production is**
  - Variable
  - Uncertain
  - Often Remotely Located
  - Not highly correlated in time with system load
- **Capacity credit 10-30% of nameplate for long range planning purposes**


# Tehachapi Wind Generation in April – 2005

Variable and Uncertain




# Wind generation tends to be inversely correlated to daily system load

CAISO Load -- Fall 2006




Total Wind -- Fall 2006




Total Wind

# Wind vs. Actual Load on a Typical Hot Day in 2006



# Wind Generation Summer 2007 – 5 Hottest Days

CAISO Load Data



# *Lets Look at the Technologies in California*

## *Solar Characteristics*

- **Higher cost on an energy basis**
- **Several technologies**
  - Thermal (central tower, trough, Sterling, etc)
  - Thermal with storage or supplemental gas firing
  - PV roof top
  - PV large scale (> 1MW)
- Insolation is variable but absent clouds relatively certain
- With clouds, production is less certain
- Solar production correlates with system load
- Technologies with larger thermal mass tend to filter out short term variability (e.g solar thermal)
- Solar Capacity Credit 60% – 95% (depending upon technology) for the purpose of long range planning


# *Lets Look at the Technologies in California Solar Thermal Generation*



**Solar II Solar Central Receiver**



**Trough Design**



**eSolar's Modular Solar Power Plant Concept**

# *Lets Look at the Technologies in California Solar PV*




# *Solar Insolation Examples – Sacramento Area*

- **Spring 2009 data collected at SMUD PV site**
- **Data is collected at 1 minute intervals**
- **Several days shown in first week of March and May**
- **Indicative of Solar production, especially PV**


**Source: <http://www.nrel.gov/midc/>**

# Solar Insolation Examples – Sacramento

## March 7




# Solar Insolation Examples – Sacramento March 5




# Solar Insolation Examples – Sacramento March 2


March 2, 2009



# Solar Insolation Examples – Sacramento May 5



# Typical Daily Wind vs. Solar Generation Pattern Shows Complimentary Nature



# *System Operations – Renewable Integration*

- Regulation (second to second Auto Generation Control) and Ramping ( minute to minute) requirements affected by amount of renewables and the type
- Unit commitment to cover the peak plus reserves
- Variability and Uncertainty (forecast error) contribute to increased requirements
- Nexant study results

# System Operations – Renewable Integration Requirements Regulation and Ramping Nexant Study

Morning Ramps				
	CAISO 2006	CAISO 20% 2013	Statewide 20% 2025	Statewide 33% 2025
Winter	6,979	8,631	10,243	12,184
Spring	6,860	8,494	10,967	13,272
Summer	10,090	12,664	17,823	18,727
Fall	7,229	8,995	11,016	11,950

Evening Ramps				
	CAISO 2006	CAISO 20% 2013	Statewide 20% 2025	Statewide 33% 2025
Winter	7,856	9,293	12,090	13,483
Spring	7,962	9,783	11,854	13,497
Summer	10,589	12,135	15,938	16,330
Fall	11,511	13,483	14,167	15,851

- Includes effects of load and wind only (not solar); results understates needs
- Regulation for 33% RPS in 2020 = 541 MW Up, 559 MW Down, vs. +/- 350 MW today

# *System Operations – Renewable Integration*


- Over-generation potential increases with renewables
- Overgen occurs when inflexible generation exceeds load plus planned exports
- “Energy Dump” occurs when over-gen can not be sold to willing buyers in neighboring areas
- Nexant studies indicate
  - **Technology dependent**
  - **With high solar penetration can occur during high load hours**

# *System Operations – Renewable Integration Overgen/Dump Energy – Nexant Results*

- Most likely to happen in March-May period when hydro, wind and solar production can all be high and on weekends when load is low
- In simulations, more than 90% of dump occurs in SCE territory
- Simulation understates dump due to simplified transmission model used in production simulation and normal hydro conditions assumed
- May require changes in current and future contract structure to allow more frequent curtailment, as well as needing to reduce minimum generation levels

# Results – Dump Energy for 50% RPS

- ◆ Storage Technologies reduce dump energy




- ◆ Conditions on a day with solar and wind conditions both high... 50% RPS

# *33% Implementation Challenges - Transmission*

- Long lead time to build transmission
- Uncertain which generation projects will develop
- Uncertain where transmission upgrades will be needed
- CPUC study shows need for up to 7 new major high voltage transmission projects
- Indicative Nexant results

# Nexant Results – Transmission Expansion

## Bulk Transmission Upgrades For 33% RPS – 2020



# 33% Implementation Challenges - Transmission

## *Potential Source of Multi-Year Delay for HV Transmission*

- **Typical lead-time 6-11 years**
- **Typical process involves:**
  - Project study and approval by CAISO (1-2 years)
  - CPUC approval (2-3 years)
    - Can add significant delays, e.g., delay in approval of Sunrise Project
    - Other litigation post CPUC approval can also delay the project
  - Engineering/Procurement (1-3 years)
  - Construction/Environmental Mitigation (2-3) years
    - Delays could be based on the route and degree of environmental mitigation

# *33% Implementation Challenges - Resources*

- **Need for non-renewables dependent upon renewable mix**
- **For example a high wind case would require more “capacity” to meet Planning Margin than a high solar**
  - 3000 MW needed for Wind (10,000 MW) and Solar (2,000 MW)
  - 300 MW needed for Wind (4000 MW) and Solar (8000 MW)
  - Assuming wind at 15% and solar at 60% capacity credit
- **Regulation and ramping needs are dependent upon renewable mix**
  - Not well understood at this time for full mix of renewables
  - CAISO 33% RPS Integration studies underway to clarify requirements

## *What are the opportunities to address these challenges*

- Focused geographical development to streamline transmission siting to reduce the time to build transmission
- Improved longer term analytical tools to help narrow the uncertainty as 2020 approaches - more probabilistic
- PRM may have to be expanded to include integration requirements
- Potential increased use of distributed generation to reduce the transmission delays associated with larger scale remote wind and solar

## *What are the opportunities to address these challenges*

- Improved control over new wind and solar to deal with severe ramps and over-gen events
- Potential increased role for storage and demand side responses to address regulation, ramps and over-gen
- Improved wind forecasting to reduce daily uncertainty and thus reduce regulation and load following requirements
- Improved solar generation forecasting through better cloud cover forecasting to reduce daily uncertainty

# Questions

- Questions?