9/17/13 Q&R C37.10.1 VC

- Minutes were verbally discussed, then approved
  - 1st by: John Webb 2nd by: by Stan Billings
- Review/ revision of table of parameters:
  - Trickle current may not be the best, most reliable method. Bette options do exist
  - I^2t covered by 'accumulate fault current section '
  - Circuit integrity changed 'relay' to measurement
  - Insulation medium currently only addresses 'Gas'.
    - Make a note somewhere about gas contamination
    - Replaced 'quality' with 'status'
  - Comment was made that table may be better as two.
  - Chair asked for volunteers to review and revise tables presented:
    - Todd Irwin, Mauricio A, Vernon, John Hall, Pat Dilillo will look at transmission table
    - John Webb, Eldridge Byron, Pat Dilillo, Steven Chen to review/revise distribution table
  - Definition of monitoring was questioned: monitoring can be online, local, data acquisition, etc…
  - Eldridge Byron, Pat Dilillo and Devki Sharma to review and compare table 3 in C37.10.1 to the presented tables

Meeting attendance

Last	***First***		***Company***
Alexander	Roy	M	RWA Engineering
Brown	Steven	M	Allen & Hoshall
Cantrelle	Don	M	Southern Company
Cary	Steven	M	Eaton
Chin	Steven	M	Eaton
Chow	Chih	M	PEPCO
Collette	Dave	G	MEPPI
Day	Jerod	M	Vacuum Interrupters
Dufourmet	Denis	M	ALSTOM Grid
Edwards	Doug	G	Siemens
Esco	Tanner	G	Eaton
Irwin	Todd	M	ALSTOM Grid
Issac	Carlos	M	Oncor Electric Delivery
Mulcahy	Tom	M	Dominion
Pellerito	Tom	M	DTE Energy
Ricciuti	Anthony	M	Eaton
Rodgers	Jon	M	Siemens

Last	*First*		*Company*
Schuetz	Carlos	M	ATC
Toups	Vernon	M	Siemens
Barrio	Bob	G	Parsons
Roberts	Brian	G	Southern States
Ahmed	Shahab	G	Siemens
Aristizabal	Mauricio	M	ABB
Billings	Stan	M	MEPPI
Bufi	Arben	M	Hitachi HVB
Byron	Eldridge	M	Scheider Electric
Carmona	Gilbert	M	Southern California Edison
DiLillo	Pat	M	Consolidated Edison of NY
Giraud	Douglas	M	Powell electric
Hall	John	G	TVA
Lofgren	Bjorn	G	Siemens
Marshall	Vincent	G	Southern Company
Marzec	Peter	M	S&C Electric
Palazzo	Mirko	M	ABB
Peterson	Alan	G	Utility Service Corporation
Sauls	Roderick	M	Southern Company
Sharma	Devki	M	Consultant
Shinde	Sushil	M	ABB
Webb	John	M	ABB
Becker	George	M	United Illuminating
Yoon	DongSun	G	HICO America
Spiewak	Erin	G	IEEE SA
Ciofoni	Reggero	G	Altalink